

PUBLIC NOTICE

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER FAILURE TO MONITOR

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

Monitoring Requirements Not Met for Lake Noxen Elementary School

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2024 we failed to monitor for the following contaminants and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, the required sampling frequency, how many samples we took, when samples should have been taken, and the date on which corrective action samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
SOC's (See attached full list of monitoring chemicals)	Quarterly	Samples were taken in the first and second quarter of 2024	All four quarters of 2024	Samples will be taken quarterly in 2025. The first sample was taken on 3/4/2025

What happened? What was done? When will it be resolved?

SOC samples were taken in the first and second quarters in 2024. Third and fourth quarters were not taken and mandated by the DEP. Four consecutive quarters of sampling are required. The first of the four consecutive monitoring requirements was taken on 3/4/2025. All reported results drawn in 2024 were non-detectable and meet all DEP requirements.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information regarding this notice, please contact Utility Management and Environmental Services at 570-592-4155.

Certified by:

Signature: Mark Krofchok

Date: 3/7/2025

Print Name and Title: Mark Krofchok- Owner/Operator



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SAFE DRINKING WATER

As a representative of the Public Water system indicated above, I certify that public notification addressing the above violation was distributed to all customers in accordance with the delivery requirements outlined in Chapter 25 PA Code 109 Subchapter D of the Department of Environmental Protection (DEP's) regulations. The following methods of distribution were used: Posted at entrance, posted on website

PWS ID#: 2400375Date distributed: 3/7/2025**SOC List**

ENDRIN (SOC)	
LINDANE (SOC)	
METHOXYCHLOR (SOC)	
TOXAPHENE (SOC)	
DALAPON (SOC)	
DIQUAT (SOC)	
GLYPHOSATE (SOC)	
DI(2-ETHYLHEXYL)ADIPATE (SOC)	
OXAMYL (VYDATE) (SOC)	
SIMAZINE (SOC)	
DI(2-ETHYLHEXYL)PHTHALATE (SOC)	
PICLORAM (SOC)	
DINOSEB (SOC)	
HEXACHLOROCYCLOPENTADIENE(SOC)	
CARBOFURAN (SOC)	
ATRAZINE (SOC)	
ALACHLOR (SOC)	
2,3,7,8-TCDD (DIOXIN) (SOC)	
HEPTACHLOR (SOC)	
HEPTACHLOR EPOXIDE (SOC)	
2,4-D (SOC)	
2,4,5-TP SILVEX (SOC)	



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SAFE DRINKING WATER

HEXACHLOROBENZENE (SOC)	
BENZO(A)PYRENE (SOC)	
PENTACHLOROPHENOL (SOC)	
PCBS (SOC)	
1,2-DIBROMO-3-CHLOROPROP(SOC)	
ETHYLENE DIBROMIDE (EDB) (SOC)	
CHLORDANE (SOC)	